CITY OF SPRINGFIELD INTER-OFFICE MEMORANDUM

ATTENTION OF	File	DATE	9/27/88
DEPARTMENT			

Re: Gasoline in sewer adjacent to 213 S. Scenic

In reference to the gasoline in the sewer problems in the 3000 block Mt. Vernon over the weekend, Steve Short and Bob Corson checked the sewer line adjacent to the Scenic Oil Co., 213 S. Scenic. A wastewater sample was collected from the sewer and it contained a small amount of what appears to be gasoline. LEL readings were 10% at manhole 39, Wye Map 0-5, and 5% at manhole #17, Wye Map 0-5.

I contacted the owner of the Scenic Oil Co., Ed Miller 334-4930, about our findings. He said that he would have Stoddard Equipment Co. check his system for leaks and would contact this office so that we could observe the testing.

cc: file

IGNED Bob Corson

Bob Corson WPCI III S&E

213 S. Scenio